

**C**

# **Biotreatment Soil Media Specifications**

## **Table of Contents**

- C.1: Introduction
- C.2: BASMAA Regional Biotreatment Soil Media Specification and BSM Supplier List
- C.3: SCVURPPP Biotreatment Soil Media Specification Verification Checklist

## **C.1 Introduction**

The MRP requires Regulated Projects to use biotreatment soil media that meet the minimum specifications set forth in Attachment L of MRP 1.0 (Order No. R2-2009-0074). The MRP also allows Permittees to collectively develop and adopt revisions to the soil media minimum specifications subject to the Water Board Executive Officer's approval. On February 5, 2016, Permittees submitted revisions to the soil media specifications to address issues with the current soil media specifications that Permittees have identified, based on implementation of these soil media specifications for 5 years under the previous MRP. The Water Board Executive Officer approved the revised soil specifications on April 18, 2016. This appendix contains the revised biotreatment soil media (BSM) specifications. All Regulated Projects are required to use these revised BSM specifications.

To assist permittees and others in complying with this requirement, the Program has produced several documents including a guidance memorandum, a BSM Supplier List, and a BSM Verification Checklist to review the supplied soil media. To access the documents, see: <https://scvurppp.org/2016/04/18/basmaa-regional-biotreatment-soil-specification-2016/> or go to <https://scvurppp.org/2021/07/01/biotreatment-soil-media-supplier-list/>.

**SANTA CLARA VALLEY URBAN RUNOFF POLLUTION PREVENTION PROGRAM**

In 2014, the Program vetted several BSM suppliers and created a vendor list. The list is amended annually as other suppliers submit verification information. The Program provides this list of BSM suppliers for the use of its member agencies, contractors, designers and others in finding suppliers for their projects. Suppliers are listed based on a general review of their BSM product including test results, adherence to the BSM specification in the MRP and knowledge of the specification. Users of the vendor list must make the final determination as to the products and adherence to the MRP. The listing of any BSM supplier is not to be construed as an actual or implied endorsement, recommendation, or warranty of such BSM supplier or their products, nor is criticism implied of similar BSM suppliers that are not listed.

## **C.2 BASMAA Regional Biotreatment Soil Specification**

### **Specification of Soils for Biotreatment or Bioretention Facilities**

**April 18, 2016**

Soils for biotreatment or bioretention areas shall meet two objectives:

- Be sufficiently permeable to infiltrate runoff at a minimum rate of 5" per hour during the life of the facility, and
- Have sufficient moisture retention to support healthy vegetation.

Achieving both objectives with an engineered soil mix requires careful specification of soil gradations and a substantial component of organic material (typically compost).

Local soil products suppliers have expressed interest in developing ‘brand-name’ mixes that meet these specifications. At their sole discretion, municipal construction inspectors may choose to accept test results and certification for a ‘brand-name’ mix from a soil supplier.

Tests must be conducted within 120 days prior to the delivery date of the bioretention soil to the project site.

Batch-specific test results and certification shall be required for projects installing more than 100 cubic yards of bioretention soil.

#### **SOIL SPECIFICATIONS**

Bioretention soils shall meet the following criteria. “Applicant” refers to the entity proposing the soil mixture for approval by a Permittee.

1. General Requirements – Bioretention soil shall:
  - a. Achieve a long-term, in-place infiltration rate of at least 5 inches per hour.
  - b. Support vigorous plant growth.
  - c. Consist of the following mixture of fine sand and compost, measured on a volume basis:
    - 60%-70% Sand
    - 30%-40% Compost
2. Submittal Requirements – The applicant shall submit to the Permittee for approval:
  - a. A minimum one-gallon size sample of mixed bioretention soil.

- b. Certification from the soil supplier or an accredited laboratory that the Bioretention Soil meets the requirements of this guideline specification.
- c. Grain size analysis results of the fine sand component performed in accordance with ASTM D 422, Standard Test Method for Particle Size Analysis of Soils or Caltrans Test Method (CTM) C202.
- d. Quality analysis results for compost performed in accordance with Seal of Testing Assurance (STA) standards, as specified in 4.
- e. Organic content test results of mixed Bioretention Soil. Organic content test shall be performed in accordance with by Testing Methods for the Examination of Compost and Composting (TMECC) 05.07A, “Loss-On-Ignition Organic Matter Method”.
- f. Grain size analysis results of compost component performed in accordance with ASTM D 422, Standard Test Method for Particle Size Analysis of Soils.
- g. A description of the equipment and methods used to mix the sand and compost to produce Bioretention Soil.
- h. Provide the name of the testing laboratory(s) and the following information:
  - (1) Contact person(s)
  - (2) Address(s)
  - (3) Phone contact(s)
  - (4) E-mail address(s)
  - (5) Qualifications of laboratory(s), and personnel including date of current certification by USCC, ASTM, Caltrans, or approved equal

**3. Sand for Bioretention Soil**

- a. Sand shall be free of wood, waste, coating such as clay, stone dust, carbonate, etc., or any other deleterious material. All aggregate passing the No. 200 sieve size shall be nonplastic.
- b. Sand for Bioretention Soils shall be analyzed by an accredited lab using #200, #100, #40 or #50, #30, #16. #8, #4, and 3/8 inch sieves (ASTM D 422, CTM 202 or as approved by municipality), and meet the following gradation:

| Sieve Size      | Percent Passing (by weight) |            |
|-----------------|-----------------------------|------------|
|                 | <i>Min</i>                  | <i>Max</i> |
| 3/8 inch        | 100                         | 100        |
| No. 4           | 90                          | 100        |
| No. 8           | 70                          | 100        |
| No. 16          | 40                          | 95         |
| No. 30          | 15                          | 70         |
| No. 40 or No.50 | 5                           | 55         |
| No. 100         | 0                           | 15         |
| No. 200         | 0                           | 5          |

Note: all sands complying with ASTM C33 for fine aggregate comply with the above gradation requirements.

#### 4. Composted Material

Compost shall be a well decomposed, stable, weed free organic matter source derived from waste materials including yard debris, wood wastes or other organic materials not including manure or biosolids meeting the standards developed by the US Composting Council (USCC). The product shall be certified through the USCC Seal of Testing Assurance (STA) Program (a compost testing and information disclosure program).

- a. Compost Quality Analysis by Laboratory – Before delivery of the soil, the supplier shall submit a copy of lab analysis performed by a laboratory that is enrolled in the US Composting Council’s Compost Analysis Proficiency (CAP) program and using approved Test Methods for the Examination of Composting and Compost (TMECC). The lab report shall verify:
- (1) Organic Matter Content: 35% - 75% by dry wt.
  - (2) Carbon and Nitrogen Ratio: C:N < 25:1 and C:N >15:1
  - (3) Maturity/Stability: Any one of the following is required to indicate stability:
    - (i) Oxygen Test < 1.3 O<sub>2</sub> /unit TS /hr
    - (ii) Specific oxy. Test < 1.5 O<sub>2</sub> / unit BVS /hr
    - (iii) Respiration test < 8 mg CO<sub>2</sub>-C /g OM / day
    - (iv) Dewar test < 20 Temp. rise (°C) e.
    - (v) Solvita® > 5 Index value
  - (4) Toxicity: Any one of the following measures is sufficient to indicate non-toxicity.
    - (i) NH<sub>4</sub><sup>+</sup> : NO<sub>3</sub><sup>-</sup>-N < 3
    - (ii) Ammonium < 500 ppm, dry basis
    - (iii) Seed Germination > 80 % of control
    - (iv) Plant Trials > 80% of control
    - (v) Solvita® = 5 Index value
  - (5) Nutrient Content: provide analysis detailing nutrient content including N-P-K, Ca, Na, Mg, S, and B.
    - (i) Total Nitrogen content 0.9% or above preferred.
    - (ii) Boron: Total shall be <80 ppm;
  - (6) Salinity: Must be reported; < 6.0 mmhos/cm
  - (7) pH shall be between 6.2 and 8.2 May vary with plant species.
- b. Compost Quality Analysis by Compost Supplier – Before delivery of the compost to the soil supplier the Compost Supplier shall verify the following:
- (1) Feedstock materials shall be specified and include one or more of the following: landscaping/yard trimmings, grass clippings, food scraps, and agricultural crop residues.

- (2) Maturity/Stability: shall have a dark brown color and a soil-like odor. Compost exhibiting a sour or putrid smell or containing recognizable grass or leaves, or is hot (120F) upon delivery or rewetting is not acceptable.
- (3) Weed seed/pathogen destruction: provide proof of process to further reduce pathogens (PFRP). For example, turned windrows must reach min. 55C for 15 days with at least 5 turnings during that period.

c. Compost for Bioretention Soil Texture – Compost for bioretention soils shall be analyzed by an accredited lab using #200, 1/4 inch, 1/2 inch, and 1 inch sieves (ASTM D 422 or as approved by municipality), and meet the following gradation:

| Sieve Size | Percent Passing (by weight) |            |
|------------|-----------------------------|------------|
|            | <i>Min</i>                  | <i>Max</i> |
| 1 inch     | 99                          | 100        |
| 1/2 inch   | 90                          | 100        |
| 1/4 inch   | 40                          | 90         |
| No. 200    | 1                           | 10         |

- d. Bulk density shall be between 500 and 1100 dry lbs/cubic yard
- e. Moisture content shall be between 30% - 55% of dry solids.
- f. Inerts – compost shall be relatively free of inert ingredients, including glass, plastic and paper, < 1 % by weight or volume.
- g. Select Pathogens – Salmonella <3 MPN/4grams of TS, or Coliform Bacteria <10000 MPN/gram.
- h. Trace Contaminants Metals (Lead, Mercury, Etc.) – Product must meet US EPA, 40 CFR 503 regulations.
- i. Compost Testing – The compost supplier will test all compost products within 120 calendar days prior to application. Samples will be taken using the STA sample collection protocol. (The sample collection protocol can be obtained from the U.S. Composting Council, 4250 Veterans Memorial Highway, Suite 275, Holbrook, NY 11741 Phone: 631-737-4931, [www.compostingcouncil.org](http://www.compostingcouncil.org)). The sample shall be sent to an independent STA Program approved lab. The compost supplier will pay for the test.

## **VERIFICATION OF ALTERNATIVE BIORETENTION SOIL MIXES**

Bioretention soils not meeting the above criteria shall be evaluated on a case by case basis. Alternative bioretention soil shall meet the following specification: “Soils for bioretention facilities shall be sufficiently permeable to infiltrate runoff at a minimum rate of 5 inches per hour during the life of the facility, and provide sufficient retention of moisture and nutrients to support healthy vegetation.”

The following steps shall be followed by municipalities to verify that alternative soil mixes meet the specification:

1. General Requirements – Bioretention soil shall achieve a long-term, in-place infiltration rate of at least 5 inches per hour. Bioretention soil shall also support vigorous plant growth. The applicant refers to the entity proposing the soil mixture for approval.
  - a. Submittals – The applicant must submit to the municipality for approval:
    - (1) A minimum one-gallon size sample of mixed bioretention soil.
    - (2) Certification from the soil supplier or an accredited laboratory that the Bioretention Soil meets the requirements of this guideline specification.
    - (3) Certification from an accredited geotechnical testing laboratory that the Bioretention Soil has an infiltration rate between 5 and 12 inches per hour as tested according to Section 1.b.(2)(ii).
    - (4) Organic content test results of mixed Bioretention Soil. Organic content test shall be performed in accordance with by Testing Methods for the Examination of Compost and Composting (TMECC) 05.07A, “Loss-On-Ignition Organic Matter Method”.
    - (5) Grain size analysis results of mixed bioretention soil performed in accordance with ASTM D 422, Standard Test Method for Particle Size Analysis of Soils.
    - (6) A description of the equipment and methods used to mix the sand and compost to produce Bioretention Soil.
    - (7) The name of the testing laboratory(s) and the following information:
      - (i) Contact person(s)
      - (ii) Address(s)
      - (iii) Phone contact(s)
      - (iv) E-mail address(s)
      - (v) Qualifications of laboratory(s), and personnel including date of current certification by STA, ASTM, or approved equal.
  - b. Bioretention Soil
    - (1) Bioretention Soil Texture: Bioretention Soils shall be analyzed by an accredited lab using #200, and 1/2” inch sieves (ASTM D 422 or as approved by municipality), and meet the following gradation:

| Sieve Size | Percent Passing (by weight) |            |
|------------|-----------------------------|------------|
|            | <i>Min</i>                  | <i>Max</i> |
| 1/2 inch   | 97                          | 100        |
| No. 200    | 2                           | 5          |

- (2) Bioretention Soil Permeability testing: Bioretention Soils shall be analyzed by an accredited geotechnical lab for the following tests:
- (i) Moisture – density relationships (compaction tests) shall be conducted on bioretention soil. Bioretention soil for the permeability test shall be compacted to 85 to 90 percent of the maximum dry density (ASTM D1557).
  - (ii) Constant head permeability testing in accordance with ASTM D2434 shall be conducted on a minimum of two samples with a 6-inch mold and vacuum saturation.

**MULCH FOR BIORETENTION FACILITIES**

Three inches of mulch is recommended for the purpose of retaining moisture, preventing erosion and minimizing weed growth. Projects subject to the State’s Model Water Efficiency Landscaping Ordinance (or comparable local ordinance) will be required to provide at least three inches of mulch. Aged mulch, also called compost mulch, reduces the ability of weeds to establish, keeps soil moist, and replenishes soil nutrients. Aged mulch can be obtained through soil suppliers or directly from commercial recycling yards. It is recommended to apply 1" to 2" of composted mulch, once a year, preferably in June following weeding.

**C.3 Biotreatment Soil Media Specification Verification Checklist**

The BSM Verification Checklist was developed to assist permittee staff, contractors, designers and others in the review of BSM submittals from BSM suppliers with an easy-to-read summary of the detailed information needed to verify that the BSM being provided by the BSM supplier meets the BSM specification. The checklist is divided into four parts for each of the four parties involved with the testing and production of the BSM product: the BSM supplier, the sand supplier and testing laboratory, the compost supplier and the compost testing laboratory. Each party is required to fill out their section of the checklist. The design team and permittee staff can then easily review the filled-in and checked boxes which are mostly structured as pass/fail answers. The checklist was most recently updated in 2021 with the current program websites. Municipal agencies have different needs and may want to design their review processes accordingly. Some agencies may want to go through a detailed process with the BSM checklist every time or only with their own agency projects. Others may want to do that only with first-time contractors or for a few projects until everyone is familiar with the process.

# Biotreatment Soil Media

## Specification Verification Checklist

---

This checklist is intended to supply municipal staff, contractors, designers and others with an easy-to-read summary of the information needed to verify that the biotreatment soil media being provided by the soil media supplier meets the soil media specification in the Bay Area Stormwater Management Agencies Association (BASMAA) “Specification of Soils for Biotreatment or Bioretention Facilities” dated April 18, 2016. The checklist should be provided to the soil media supplier by the municipality or contractor before the soil media has been ordered to allow for sufficient time to compile the information and time to review the completed checklist before delivery of the soil media to the job site.

Use of this checklist is not required by the MRP and is intended only for assistance in reviewing submittals. Additionally or alternatively, the one page Supplier Certification Statement, developed by the stormwater programs listed below, can be requested from the Supplier to guarantee that the product meets the specification.

The Certification Statement, a list of soil media suppliers, the BASMAA specification and other materials are available at the following websites:

- Santa Clara Valley Urban Runoff Pollution Prevention Program:  
[www.scvurppp.org/newdev/](http://www.scvurppp.org/newdev/)
- San Mateo Countywide Water Pollution Prevention Program:  
[www.flowstobay.org/preventing-stormwater-pollution/with-new-redevelopment/c-3-regulated-projects/](http://www.flowstobay.org/preventing-stormwater-pollution/with-new-redevelopment/c-3-regulated-projects/)
- Alameda Countywide Clean Water Program:  
[www.cleanwaterprogram.org/businesses/development.html](http://www.cleanwaterprogram.org/businesses/development.html)

If a municipality chooses to use the checklist, the following five items are required to be submitted by the soil media Supplier to the requesting municipality or contractor:

- **Sample of the Biotreatment Soil Media**  
A minimum 1-gallon bag of soil media.
- **Attachment A – Supplier Analysis of the Biotreatment Soil Media**  
*To be completed by the soil media supplier staff providing the soil media.*
- **Attachment B – Lab Analysis of Sand Component of the Biotreatment Soil Media**  
*To be completed by the laboratory staff conducting the analysis of the sand.*
- **Attachment C – Lab Analysis of Compost Component of the Biotreatment Soil Media**  
*To be completed by the laboratory staff conducting the analysis of the compost. Compost analysis of a sample collected (in accordance with the Seal of Testing Assurance [STA] sample collection protocol) shall be completed within the last 120 days. Analysis must be completed by a laboratory enrolled in the US Composting Council’s (USCC) Compost Analysis Proficiency (CAP) program, and shall use the Test Methods for the Examination of Composting and Compost (TMECC).*
- **Attachment D – Supplier Analysis of Compost Component of the Biotreatment Soil Media**  
*To be completed by the compost supplier staff providing the compost component of the soil media.*

# Attachment A

## Supplier Analysis of Biotreatment Soil Media

The table below shall be completed by the biotreatment soil media supplier staff.

|  |                                     |  |                                     |                          |
|--|-------------------------------------|--|-------------------------------------|--------------------------|
| <b>Date:</b>   |                                     | <b>Name of Person Filling Out This Form:</b> |                                     |                          |
| <b>(All lab tests must be done within the last 120 days)</b>   |                                     |  |                                     |                          |
| <b>Title:</b>  |                                     | <b>Signature:</b>                            |                                     |                          |
| <b>Phone:</b>  |                                     | <b>Email:</b>                                |                                     |                          |
| <b>Company Name:</b>   |                                     | <b>City:</b>                                 |                                     |                          |
| <b>Street Address:</b>   |                                     | <b>Zip:</b>                                  |                                     |                          |
| I certify that the provided biotreatment soil media meets the requirements of the BASMAA 2016 specification.   |                                     | <input type="checkbox"/> Yes (Pass)          |                                     |                          |
|  |                                     | <input type="checkbox"/> No (Fail)           |                                     |                          |
| Describe the equipment and methods used to mix the compost and sand components of the biotreatment soil media. |                                     |  |                                     |                          |
| <b>Material</b>  | <b>Standard Percent (by volume)</b> | <b>Actual Media %</b>                        | <b>Pass</b>                         | <b>Fail</b>              |
| Sand   | 60% - 70%                           |  | <input type="checkbox"/>            | <input type="checkbox"/> |
| Compost  | 30% - 40%                           |  | <input type="checkbox"/>            | <input type="checkbox"/> |
| Does the soil media have a permeability of at least 5 inches per hour? <sup>1</sup>                            |                                     |  | <input type="checkbox"/> Yes (Pass) |                          |
|  |                                     |  | <input type="checkbox"/> No (Fail)  |                          |
| Will the soil media support vigorous plant growth?   |                                     |  | <input type="checkbox"/> Yes (Pass) |                          |
|  |                                     |  | <input type="checkbox"/> No (Fail)  |                          |

<sup>1</sup>Soil media permeability testing is only required for alternative biotreatment soil media. Soil permeability tests must be conducted on a minimum of two samples using constant head permeability in accordance with ASTM D2434 with a 6-inch mold and vacuum saturation.

# Attachment B

## Lab Analysis of Sand Component of Biotreatment Soil Media

The table below shall be completed by the laboratory staff conducting the sand analysis.

| <b>Name of Person Filling Out This Form:</b>   |  |  |                     |  | <b>Signature:</b>                   |                          |  |  |  |
|--|--|--|---------------------|--|-------------------------------------|--------------------------|--|--|--|
| <b>Title:</b>  |  |  |                     |  | <b>Date:</b>                        |                          |  |  |  |
| <b>Phone:</b>  |  |  |                     |  | <b>Email:</b>                       |                          |  |  |  |
| <b>Company:</b>  |  |  |                     |  | <b>City:</b>                        |                          |  |  |  |
| <b>Street Address:</b>   |  |  |                     |  | <b>Zip:</b>                         |                          |  |  |  |
| <b>Qualifications &amp; relevant certifications (ASTM, CTM or approved equivalent certifications):</b>   |  |  |                     |  |                                     |                          |  |  |  |
| Is sand free of wood, waste, coating (such as clay, stone dust, carbonate, etc.), or any other deleterious material?   |  |  |                     |  | <input type="checkbox"/> Yes (Pass) |                          |  |  |  |
|  |  |  |                     |  | <input type="checkbox"/> No (Fail)  |                          |  |  |  |
| Is all aggregate passing the No. 200 sieve non-plastic?  |  |  |                     |  | <input type="checkbox"/> Yes (Pass) |                          |  |  |  |
|  |  |  |                     |  | <input type="checkbox"/> No (Fail)  |                          |  |  |  |
| Particle size analysis shall be conducted in accordance with ASTM D 422 (Standard Test Method for Particle Size Analysis of Soils) or CTM 202. Other equivalent methods acceptable only if approved. |  |  |                     |  |                                     |                          |  |  |  |
| Sieve Size   | Standard Percent Passing (% by weight) |  | Testing Results (%) |  | Pass                                | Fail                     |  |  |  |
| 3/8 inch   | 100%                                   |  |                     |  | <input type="checkbox"/>            | <input type="checkbox"/> |  |  |  |
| No. 4  | 90% - 100%                             |  |                     |  | <input type="checkbox"/>            | <input type="checkbox"/> |  |  |  |
| No. 8  | 70% - 100%                             |  |                     |  | <input type="checkbox"/>            | <input type="checkbox"/> |  |  |  |
| No. 16   | 40% - 95%                              |  |                     |  | <input type="checkbox"/>            | <input type="checkbox"/> |  |  |  |
| No. 30   | 15% - 70%                              |  |                     |  | <input type="checkbox"/>            | <input type="checkbox"/> |  |  |  |
| No. 40 or 50   | 5% - 55%                               |  |                     |  | <input type="checkbox"/>            | <input type="checkbox"/> |  |  |  |
| No. 100  | 0% - 15%                               |  |                     |  | <input type="checkbox"/>            | <input type="checkbox"/> |  |  |  |
| No. 200  | 0% - 5%                                |  |                     |  | <input type="checkbox"/>            | <input type="checkbox"/> |  |  |  |

# Attachment C

## Lab Analysis of Compost Component of Biotreatment Soil Media

The table below shall be completed by the laboratory staff conducting the compost analysis.

|  |                   |
|--|-------------------|
| <b>Name of Person Filling Out This Form:</b>   | <b>Signature:</b> |
| <b>Title:</b>  | <b>Date:</b>      |
| <b>Phone:</b>  | <b>Email:</b>     |
| <b>Company:</b>  | <b>City:</b>      |
| <b>Street Address:</b>   | <b>Zip:</b>       |
| <b>Qualifications &amp; relevant certifications:<br/>(USCC, ASTM or approved equivalent certification)</b> |                   |

| Specification  | Standard                             | Testing Results           | Pass                     | Fail                     |
|--|--------------------------------------|---------------------------|--------------------------|--------------------------|
| <b>Organic Matter Content</b>                                      | 35% - 75%<br>(by dry weight)         | %                         | <input type="checkbox"/> | <input type="checkbox"/> |
| <b>Carbon-to-Nitrogen Ratio</b>                                    | 15:1 to 25:1 (C:N)                   | C:N                       | <input type="checkbox"/> | <input type="checkbox"/> |
| <b>Salinity</b>  | < 6.0 mm hos/cm                      | mm hos/cm                 | <input type="checkbox"/> | <input type="checkbox"/> |
| <b>pH</b>  | 6.2 - 8.2                            | pH                        | <input type="checkbox"/> | <input type="checkbox"/> |
| <b>Bulk Density</b>  | 500 – 1100 dry lbs / yd <sup>3</sup> | dry lbs / yd <sup>3</sup> | <input type="checkbox"/> | <input type="checkbox"/> |
| <b>Moisture Content</b>  | 30%-55% (of dry solids)              | %                         | <input type="checkbox"/> | <input type="checkbox"/> |
| <b>Percent inert ingredients<br/>(incl. plastic, glass, paper)</b> | < 1%<br>(by weight or volume)        | %                         | <input type="checkbox"/> | <input type="checkbox"/> |

Provide the results of at least one of the following analyses to indicate compost stability:

| Specification               | Standard                          | Testing Results               | Pass                     | Fail                     |
|-----------------------------|-----------------------------------|-------------------------------|--------------------------|--------------------------|
| <b>Oxygen Test</b>          | < 1.3 O <sub>2</sub> /unit TS/hr  | O <sub>2</sub> /unit TS/hr    | <input type="checkbox"/> | <input type="checkbox"/> |
| <b>Specific Oxygen Test</b> | < 1.5 O <sub>2</sub> /unit BVS/hr | O <sub>2</sub> /unit BVS/hr   | <input type="checkbox"/> | <input type="checkbox"/> |
| <b>Respiration Test</b>     | < 8mg CO <sub>2</sub> -C/g OM/day | mgCO <sub>2</sub> -C/g OM/day | <input type="checkbox"/> | <input type="checkbox"/> |
| <b>Dewar test</b>           | < 20 °C Temp. rise e.             | °C Temp. rise e.              | <input type="checkbox"/> | <input type="checkbox"/> |
| <b>Solvita® Index value</b> | > 5 Index value                   | Index value                   | <input type="checkbox"/> | <input type="checkbox"/> |

| Provide the results of <u>at least one</u> of the following analyses to indicate compost toxicity:  |                                      |                     |  |                                     |                          |
|---|--------------------------------------|---------------------|--|-------------------------------------|--------------------------|
| Specification   | Standard                             | Testing Results     |  | Pass                                | Fail                     |
| <b>Ratio (NH<sub>4</sub><sup>+</sup>-N: NO<sub>3</sub><sup>-</sup>-N)</b>   | < 3                                  |                     | NH <sub>4</sub> <sup>+</sup> -N: NO <sub>3</sub> <sup>-</sup> -N | <input type="checkbox"/>            | <input type="checkbox"/> |
| <b>Ammonium</b>   | < 500 ppm, dry basis                 |                     | ppm, dry basis   | <input type="checkbox"/>            | <input type="checkbox"/> |
| <b>Seed Germination</b>   | > 80% of control                     |                     | % of control   | <input type="checkbox"/>            | <input type="checkbox"/> |
| <b>Plant Trials</b>   | > 80% of control                     |                     | % of control   | <input type="checkbox"/>            | <input type="checkbox"/> |
| <b>Solvita® Index value</b>   | = 5 Index value                      |                     | Index value  | <input type="checkbox"/>            | <input type="checkbox"/> |
| Provide the analysis of the nutrient content of the compost, including the following:   |                                      |                     |  |                                     |                          |
| Specification   | Standard                             | Testing Results     |  | Pass                                | Fail                     |
| <b>Boron (total B)</b>  | < 80 ppm                             |                     | ppm  | <input type="checkbox"/>            | <input type="checkbox"/> |
| <b>Nitrogen (total N)</b>   | > 0.9% preferred                     |                     | %  |                                     |                          |
| <b>Phosphorus (as P<sub>2</sub>O<sub>5</sub>)</b>   | <i>[not specified]</i>               |                     | %  |                                     |                          |
| <b>Potassium (as K<sub>2</sub>O)</b>  | <i>[not specified]</i>               |                     | %  |                                     |                          |
| <b>Calcium (Ca)</b>   | <i>[not specified]</i>               |                     | %  |                                     |                          |
| <b>Sodium (Na)</b>  | <i>[not specified]</i>               |                     | %  |                                     |                          |
| <b>Magnesium (Mg)</b>   | <i>[not specified]</i>               |                     | %  |                                     |                          |
| <b>Sulfur (S)</b>   | <i>[not specified]</i>               |                     | ppm  |                                     |                          |
| Provide the results of <u>at least one</u> of the following select pathogens:   |                                      |                     |  |                                     |                          |
| Specification   | Standard                             | Testing Results     |  | Pass                                | Fail                     |
| <b>Salmonella</b>   | < 3 MPN/4 grams TS                   |                     | MPN/4 grams TS   | <input type="checkbox"/>            | <input type="checkbox"/> |
| <b>Coliform Bacteria</b>  | < 10,000 MPN/gram                    |                     | MPN/gram   | <input type="checkbox"/>            | <input type="checkbox"/> |
| Does the product meet US EPA, 40CFR 503 regulations regarding trace contaminants metals (Lead, Mercury, etc.)?  |                                      |                     |  | <input type="checkbox"/> Yes (Pass) |                          |
|   |                                      |                     |  | <input type="checkbox"/> No (Fail)  |                          |
| Particle size analysis shall be conducted in accordance with ASTM D 422 (Standard Test Method for Particle Size Analysis of Soils)-washing not required. Equivalent methods acceptable if approved. |                                      |                     |  |                                     |                          |
| Sieve Size  | Standard Percent Passing (by weight) | Testing Results (%) |  | Pass                                | Fail                     |
| 1 inch  | <b>99% - 100%</b>                    |                     |  | <input type="checkbox"/>            | <input type="checkbox"/> |
| ½ inch  | <b>90% - 100%</b>                    |                     |  | <input type="checkbox"/>            | <input type="checkbox"/> |
| ¼ inch  | <b>40% - 90%</b>                     |                     |  | <input type="checkbox"/>            | <input type="checkbox"/> |
| No. 200   | <b>1% - 10%</b>                      |                     |  | <input type="checkbox"/>            | <input type="checkbox"/> |

# Attachment D

## Supplier Analysis of Compost Component of Biotreatment Soil Media

The table below shall be completed by the compost supplier providing the compost for the media.

|   |  |  |  |
|---|--|--|--|
| <b>Name of Company:</b>   |  | <b>Date of Delivery:</b>   |  |
| <b>Qualifications &amp; relevant certifications:</b><br>(USCC, ASTM or approved equivalent certifications)  |  | <b>Date of the Compost Lab Analysis Report:</b><br>(Must be dated within 120 days prior to delivery) |  |
| <b>Name of Person Filling Out This Form:</b>  |  | <b>Date:</b>   |  |
| <b>Signature:</b>   |  | <b>Street Address:</b>   |  |
| <b>Email address:</b>   |  | <b>City:</b>   |  |
| <b>Phone:</b>   |  | <b>Zip:</b>  |  |
| Feedstock materials have been specified and include only the following:<br>Landscape/yard trimmings, grass clippings, food scraps, or agricultural crop residues?   |  | <input type="checkbox"/> Yes<br>(Pass)   |  |
|   |  | <input type="checkbox"/> No<br>(Fail)  |  |
| Compost has a dark brown color and a soil-like odor, does not exhibit a sour or putrid smell, does not contain recognizable grass or leaves, and is not hot (120°F) upon delivery or rewetting?             |  | <input type="checkbox"/> Yes<br>(Pass)   |  |
|   |  | <input type="checkbox"/> No<br>(Fail)  |  |
| The compost has gone through the process to further reduce pathogens (PFRP)? For example, turned windrows must reach a minimum temperature of 55°C for 15 days with at least 5 turnings during that period. |  | <input type="checkbox"/> Yes<br>(Pass)   |  |
|   |  | <input type="checkbox"/> No<br>(Fail)  |  |